



(asbl/vzw)

Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve - BELGIUM
Tel : 32 2 234 36 10 Fax: 32 2 234 36 17

Email : cert@anpi.be

EC-CERTIFICATE OF CONFORMITY

1134 - CPD - 046

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Electrical automatic control and delay devices **LIMOTEC MD6140**

Fixed fire fighting systems – Components for gas extinguishing systems

placed on the market by

**LIMOTEC nv.
Bosstraat, 21
B – 8570 VICHTE
BELGIQUE – BELGIE**

and produced in the factory

**LIMOTEC nv.
Bosstraat, 21
B – 8570 VICHTE
BELGIQUE – BELGIE**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body **ANPI** has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard (*resp. in*)

EN 12094-1 :2003

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on **21-11-2007** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly and latest on **20-11-2011**

Brussels, the 1st of October, 2008



Ing. M. VANDENDOREN
Secrétaire Général of ANPI



(asbl/vzw)

Parc Scientifique Fleming - Granbonpré 1

B-1348 Louvain-la-Neuve - BELGIUM

Tel : 32 2 234 36 10 Fax: 32 2 234 36 17

Email : cert@anpi.be

ANNEX N° 1 to EC-CERTIFICATE OF CONFORMITY

1175 - CPD - 046

01.10.2008

The device MD6140 includes also the following optional functions of the EN 12094-1 : 2003

<i>Options with requirements</i>	
4.17	<i>Delay of the extinguishing signal</i>
4.18	<i>Signal representing the flow of extinguishing agent</i>
4.19	<i>Monitoring of the status of components</i>
4.20	<i>Emergency hold device (A)</i>
4.23	<i>Manual mode only</i>
4.26	<i>Triggering signals to equipment outside the system</i>
4.30	<i>Activation of the alarm devices with different signals</i>



Ing. M. VANDENDOREN
Secrétaire Général of ANPI